

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7270-0801:115 Page 1 of 1

CATEGORY: Heat Detectors

LISTEE: Radionics, Div. Detection Systems Inc., 130 Perinton Pkwy, Fairport, NY 14450-9199
Contact: Frank Mioduszewski *(585) 223-4060

DESIGN: Model D254 and D255 heat detectors. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, temperature rating and UL label.

APPROVAL: Listed as a system heat detector for use with Models D250 and D253 bases (CSFM Listing No. 7300-0801:114) and separately listed compatible control units.

XLF: 7270-0410:119

*Rev. 05-30-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

MAY 30, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager